

WHOLESALE TRADE



MOST CITED STANDARDS IN THE WHOLESALE INDUSTRY JANUARY 1, 2002 TO DECEMBER 31, 2002

RANK		STANDARDS CITED	NUMBER
1	1910.305(g)	Flexible cords were used as a substitute for fixed wiring where not permitted. Flexible cords were not connected to devices and fittings so that strain relief was provided, which would have prevented pull from being transmitted to joints.	24
2	1910.178	This section contains safety requirements relating to fork trucks, tractors, platform lift trucks, and motorized hand trucks.	21
2	1910.303	Electrical equipment was not free from recognized hazards that were likely to cause death and serious physical harm to employees.	21
3	1910.1200	Employers did not develop and implement a written hazard communication program for their work-places. Employers did not have a Material Safety Data Sheet (MSDS) for each hazardous chemical which they used.	20
4	1910.22	Places of employment, passageways, and storerooms were not kept clean and orderly and in a sanitary condition.	18
5	60-2	Safe workplaces and practices were not provided. Standards for an Occupational Safety and Health Program were not met.	15

RANK	STANDARDS CITED	NUMBER
5	1910.23 Every stairway floor opening was not guarded by a standard railing in accordance with requirements of this section.	15
6	1910.157 The requirements of this section apply to the placement, use, maintenance, and testing of portable fire extinguishers provided for the employees' use.	13
6	1910.305(b) Conductors entering boxes, cabinets, or fittings were not protected from abrasion, and openings through which conductors entered were not effectively closed . All pull boxes, junction boxes, and fittings were not provided with covers approved for the purpose.	13
7	1910.38 This section applies to emergency-action and fire-prevention plans required by particular HIOSH standards.	9
8	1910.304 This section contains grounding and overcurrent protection requirements for systems, circuits, and equipment.	8
9	1910.37 Exits were not marked by a readily visible sign and were not readily accessible at all times.	6
9	1910.134 Respiratory protection was not provided for employees in the workplace.	6
9	1910.176 Where mechanical handling equipment was used, sufficient safe clearances were not provided. Storage of material created a hazard.	6